



- LEGEND**
- PANEL
 - INCANDESCENT LIGHT R.L.M. DOME 150 W.
 - TOGGLE SWITCH
 - COMBINATION SWITCH & PILOT LIGHT (GREEN).
 - THERMOSTAT (CAT.# T44B, MINIKON, OR EQUIV.)
 - ALARM HORN
 - N.C. NORMALLY CLOSED CONTACT
 - N.O. " " " " " " " " " " " " " " " "
 - WIRING EXTERNAL TO AIR COND. PANEL
 - CONDUIT IMBEDDED IN CONCRETE
 - G.E. TWO PUSH BUTTON STATION CE 2945-NA1524 PAGE 1077 SEAVBAE CAT. #102

- NOTES**
1. ALL WORK TO BE DONE IN ACCORDANCE WITH B.V.P. 977 AND THE NATIONAL ELECTRICAL CODE.
 2. SIX EXISTING A.C. UNITS AND WIRING TO BE REMOVED.
 3. GUTTERS TO BE PAINTED INSIDE.
 4. NEW MAIN PANEL TO BE 3/4" PLYWOOD & TO ACCOMMODATE 60 A. DISCONNECT SWITCHES FOR LIGHTING PANELS 'B' & 'C'. AIR COND. PANEL TO BE 3/8" PLYWOOD.
 5. REMOVAL OF EYEBROW WILL NECESSITATE REROUTING OF 1 1/4" CONDUIT TO MAIN PANEL AND INSTALLATION OF MAIN PANEL WITHIN BLDG. PROPER.
 6. ELECTRICIANS TO REMOVE & REPLACE ALL SURFACE WIRING TO ACCOMMODATE JOINERS WHO WILL INSTALL NECESSARY RUNNING BOARDS ON NEW WALL SURFACES.
 7. CONTROL WIRING TO BE #14 T.W.

G.E. MAGNETIC COMB. MOTOR STARTER

CR 7008 - FORM B101A3A
TYPE 1 CASE, SIZE 0, 2 HP
60 CYC. 3 PH. 208 VOLT
CIRC. BRK. TRIP 15 AMP
2 HEATER COILS #B1D540 (2.39 A.-2.62 A.)
4 " " " " #B1D549 (5.7 A.-6.2 A.)

REQUIREMENT
3 - STARTERS { 1-1/2 HP.
 { 2-1/2 HP.
1 - WITH EXTRANORMALLY CLOSED INTERLOCK

CR 7008 - FORM B101A3H
TYPE 1 CASE, SIZE 3, 25 H.P.
60 CYC. 3 PH. 208 VOLT
CIRC. BRK. TRIP 100 A.
2 HEATER COILS #B1D593 (62.5 - 67.6)

REQUIREMENT
1 - STARTER - 20 H.P.

INDEX		REVISION		DATE	BY	DESCRIPTION
7210	M - SHT. 1	7-B-53	JFM			ADDITIONAL STARTER FOR EVAP CONDENSER
7211	M - SHT. 2					
3823	S&E - SHT. 4					

P.W.C. DRAWING NO.	8/538-3/3822	U.S. NAVAL BASE MARIANAS	GUAM, M.I.
PUBLIC WORKS CENTER			
SRF ELECTRONIC REPAIR SHOP BLDG. 67-1			
AIR CONDITIONING			
PLAN, SECTION & SCHEMATICS			
STRUCTURAL & ELECTRICAL			
APPROVED		DATE	
OFFICER IN CHARGE		11/21/1953	
P&E	7-7-53	SATISFACTORY TO:	SCALE: AS NOTED SPEC.
P&E	4-3-53	ACTIVITY	SHEET NO. 2 OF 4
TO	DATE	SIGNATURE	YARDS & DOCKS
ISSUES			DRAWING NO.

